



**Bay Architects**


18201 Gulf Freeway  
Webster, Texas 77598  
Tel 281.286.6605  
Fax 281.286.9606

**ADDENDUM NO. 07**

17 August 2010

Project: **NEW TRANSPORTATION, MAINTENANCE and AGRICULTURAL BUILDINGS**  
Channelview Independent School District

Issued by: **Bay Architects, Inc.**  
18201 Gulf Freeway  
Webster, TX 77598  
281-286-6605



Bay Project No.: **0937**

**08/17/10**

Prepared for: **Prospective Proposers**

**PART A: NOTICE TO PROPOSERS:**

1. Receipt of this Addendum shall be acknowledged on the Proposal Form. Failure to do so may subject Proposers to disqualification. Each proposer shall make necessary adjustments and submit his proposal with full knowledge of all modifications, clarification, and supplemental data included therein.
2. This Addendum forms part of the Contract Documents and shall be incorporated integrally therewith. Where provisions of the following supplemental data differ from those of previously issued documents, this Addendum shall govern.
3. The following Contract Documents have been issued to date delineating the Work (Project).

|                         |                |
|-------------------------|----------------|
| Contract Documents      | 8 July 2010    |
| Addendum No. 01 – ARCH  | 4 August 2010  |
| Addendum No. 02 – MEP   | 4 August 2010  |
| Addendum No. 03 – CIVIL | 5 August 2010  |
| Addendum No. 04 – CIVIL | 11 August 2010 |
| Addendum No. 05 – ARCH  | 13 August 2010 |
| Addendum No. 06 – MEP   | 13 August 2010 |

4. This Addendum consists of: three (3) 8-1/2x11 written pages; and one (1) 8-1/2x11 sketch **ADD-07-01**; as prepared by Kalmans Marshall Engineering, Inc. Total pages included in this Addendum: 4 pages.

**PART B: CHANGES TO PRIOR ADDENDUM**  
*“Any changes to prior issued addendum materials are listed here.”*

5. None

**PART C: CHANGES TO THE PROJECT MANUAL**

6. None

**PART D: CHANGES TO THE DRAWINGS**

7. Sheet T1.03 Technology Plan – Maintenance Area B and Mezzanine
  - A. Delete all Communications System speakers.
  
8. Sheet T2.01 Technology Details
  - A. Refer to Sketch **ADD-07-01** for revised Symbol Schedule.
  - B. Details #2 and #4, tag camera as Not In Contract.
  
9. Sheet P5.01 - PLUMBING LEGEND, NOTES, AND SCHEDULES
  - A. Add the following fixture Specifications to Schedule:

TYPE: MS-1  
DESCRIPTION: MOP SINK BASIN, 24" X 24" X 12" HIGH CORNER TYPE, PRECAST TERRAZZO WITH 6" DROPPED FRONT, STAINLESS STEEL THRESHOLD CAP, 36" HOSE WITH WALL BRACKET, 20 GAUGE TYPE 304 STAINLESS STEEL BACKSPLASH PANELS. STERN-WILLIAMS "CORLOW" SBC-1750-T35-BP-2-24.  
FAUCET: CHROME PLATED BRASS FAUCET WITH INTEGRAL SHUT OFF AND CHECK STOPS, CERAMIC DISC CARTRIDGES, VACUUM BREAKER SPOUT WITH 3/4" MALE HOSE THREADED OUTLET. VANDAL RESISTANT 369 HANDLES, ADJUSTABLE TOP BRACE AND SUPPLY ARMS. CHICAGO 445-897SRCXKCP.  
ROUGH-IN: 3" WASTE, 2" VENT, 1/2" HOT AND COLD WATER.

TYPE: ESEW-1  
DESCRIPTION: EMERGENCY SHOWER/FACE AND EYEWASH. FLOOR MOUNTED WITH STAINLESS STEEL BOWL AND SCHEDULE 80, HOT DIP GALVANIZED PIPING. CHROME PLATED STAY-OPEN BALL VALVES, STAINLESS STEEL ACTUATORS, GRAPHICS. YELLOW ABS PLASTIC SHOWER HEAD ACTIVATED BY PULL ROD, 30 GPM FLOW CONTROL. ABS PLASTIC DUAL STREAM EYE/FACE-WASH HEADS ACTIVATED BY PUSH PLATE, SELF ADJUSTING 3.5 GPM REGULATOR. FLOAT OFF COVERS SECURED WITH STAINLESS STEEL BEAD CHAINS. IN-LINE STRAINER TEE. ROTATE DRAIN TEE TO FLOOR DRAIN LOCATION. FIELD PAINT SAFETY YELLOW. ENCON 01050273 WITH 01-0520-98 STRAINER TEE.  
ROUGH-IN: 1-1/4" DOMESTIC COLD WATER. COORDINATE FINAL LOCATION/HEIGHT WITH ARCHITECTURAL DRAWINGS.

TYPE: WH-2  
DESCRIPTION: WALL HYDRANT, CONCEALED BOX TYPE, 3/4" NON-FREEZE, HOT AND COLD WATER MIXING, CHROME PLATED BRASS FINISH WITH ANTI-SIPHON VACUUM BREAKER AND LOOSE KEY. INSTALL WITH BOTTOM OF HYDRANT 24" A.F.F. PROVIDE LOCKING ACCESS PANEL AS REQUIRED TO ENSURE SERVICE ACCESS TO MIXER BODY AND INLETS. WOODFORD MODEL HCB67.  
ROUGH-IN: 3/4" HOT AND COLD WATER.

- B. Add Thermostatic mixing valve to schedule"  
TMV-4, 140 DEGREE INLET, 110 DEGREE OUTLET, 0.5 GPM  
MINIMUM FLOW, 5 GPM MAXIMUM FLOW, NO  
THERMOMETER, UNIONS, 5 PSI PRESSURE DIFFERENTIAL,  
SYMMONS NO. THERMIXER MODEL 5-120-CKX.

**PART E: RE-ISSUED SHEETS**

- 10. None


**PART F: NEW ISSUED SHEETS**

- 11. None

**END OF ADDENDUM**

## REVISED SYMBOL SCHEDULE

| SYMBOL            | DESCRIPTION (DISREGARD ITEMS NOT SHOWN ON PLANS)  |
|-------------------|---|
| <b>TECHNOLOGY</b> |   |
| ◁#                | DATA DROP. 2 DATA CABLES AND TERMINATIONS UNLESS OTHERWISE NOTED.                                 |
| ⓪                 | TEACHER'S STATION MULTI-MEDIA OUTLET  |
| Ⓢ                 | ROUGH-IN LOCATION FOR FUTURE INTERACTIVE BOARD. MOUNT J-BOX AT +84" AFF UNLESS OTHERWISE NOTED.   |
| ⓐ                 | PROJECTOR MULTI-MEDIA OUTLET  |
| Ⓜ                 | ROUGH-IN (W/ DATA CABLE) LOCATION FOR CEILING MOUNTED WIRELESS ACCESS POINT                       |
| Ⓜ                 | ROUGH-IN (W/ DATA CABLE) LOCATION FOR WALL MOUNTED WIRELESS ACCESS POINT                          |
| ⓐ                 | ROUGH-IN (W/ DATA CABLE) LOCATION FOR CEILING MOUNTED SECURITY CAMERA. RE: DETAIL #4 THIS SHEET   |
| ⓐ                 | ROUGH-IN (W/ DATA CABLE) LOCATION FOR RECESSED SECURITY CAMERA. RE: DETAIL #2 THIS SHEET          |
| ⓐ                 | ROUGH-IN (W/ DATA CABLE) LOCATION FOR RECESSED EXTERIOR SECURITY CAMERA. RE: DETAIL #2 THIS SHEET |
| ⓐ                 | CEILING MOUNTED RECESSED COMMUNICATIONS SYSTEM SPEAKER  |
| ⓐ                 | RECESSED EXTERIOR COMMUNICATIONS SYSTEM SPEAKER   |
| ⓐ                 | SPEAKER FOR LOCAL SOUND REINFORCEMENT SYSTEM  |
| ⓐ                 | MICROPHONE OUTLET   |
| ⓐ                 | REMOTE SOURCE AUDIO MIXER   |
| ⓐ                 | CEILING MOUNTED SECURITY SYSTEM MOTION SENSOR   |
| ⓐ                 | WALL MOUNTED SECURITY SYSTEM MOTION SENSOR  |
| ⓐ                 | DOOR CONTACT FOR SECURITY SYSTEM.   |
| ⓐ                 | KEYPAD  |
| ⓐ                 | CARD READER   |
| ⓐ                 | TIME CLOCK ROUGH-IN   |
| ⓐ                 | POWER POLE. REFER TO ELECTRICAL.  |



08-17-10



### BAY ARCHITECTS

18201 GULF FREEWAY  
P.O. BOX 891209  
HOUSTON, TEXAS 77289  
281.286.6605

NEW MAINTENANCE, TRANSPORTATION, & AG FACILITY ADD-07-01  
CHANNELVIEW I.S.D.

0937  
Not To Scale  
August 17, 2010  
T2.01